

ENGINEERING TOMORROW



Producing District Heating with a Supermarket Refrigeration System Presenter: Torben Green

Agenda

- Motivation
- Description of the project.
- Status and preliminary results



3 Focus areas to address Energy

From Energy Consumer to Energy "Prosumer"



Where are we producing district heating?





What do we have in Høruphav?

From Energy Consumer to Energy "Prosumer"





SuperBrugsen in Høruphav



- Area: 1000 m² from 2010
 - Compressors: 5 MT (1 VS), 4 LT
- Cooling Capacity: 160 kW
- Heating :
 - Sanitary water (1800 I tank (65 °C)
 - Floor heating/low temp coils (35 °C)
 - District heating production



Heat reclaim, Data - Høruphav

Hot tap water, tank 1800 L





What's in it for the partners?

- SuperBrugsen gets paid for energy that they would have otherwise thrown away.
- Danfoss gets an opportunity to investigate the business potential in developing a controller with a dedicated district heating application
- Sønderborg Fjernvarme continues their strategy of pursuing a greener production mix by decreasing the need for oil based production



ENGINEERING TOMORROW

Heat Reclaim explained

High discharge temperatures for CO₂ compression cycle

- Gas Cooler remove the heat from evaporator and compressor work
- In practice you get minimum 60-90 °C even with minimum compressor load and reasonable low gas cooler pressure
- Heat reclaim above 65 °C is only a limited amount of energy
- If High pressure is increased when demand is present the system can reach temperatures of 80-110 °C
- Heat reclaim above 65 °C will then be a significant amount of energy
- Gas Cooler only remove a small part of energy



Simplified CO2 refrigeration cycle



High Efficient Heat Reclaim SuperBrugsen – Høruphav, DK





High Efficient Heat Reclaim including district heating connection



Operation strategy for the district heating production

- The heat consumption of the store has priority
- Current district heating strategy is:
 - Sell all the heat that is not required by the store



Expectations

- Production of 1051 GJ per year, equivalent of 10% of the solar based district heating production
- Expected pay back time around 4 years for the district heating production.
 - The pay pack time for Superbrugsen will be below 1 year
- The district heating production will be highest during summer
 - Not a problem, because that is actually good value for Sønderborg Fjernvarme



Status of the project

- The district heating production is working and producing close the the expectation
- Online data acquisition is setup
- Data is currently being collected from the store



Preliminary results

- Approximately 2.4 GJ a day, i.e. 876 GJ per year
- Higher energy production is expected during the summer
- District heating is only produced when the local requirements for the store are satisfied



Relation to CITIES

- Investigation of more advanced district heating production strategies
- Investigation of time varying price schemes for the district heating production
- Investigation of production strategies based on actual demand from the district heating grid.
- Data from the site could be made available for relevant partners in CITIES







BACKUP

Proportions

- Capacity of the district heating plan supplying Høruphav is:
 - 5 MW oil based
 - Production capacity if the solar plant is 2700 MWh/year or equivalent to the consumption of 150 households
- Capacity of district heating production from Superbrugsen is 40 kW
- The expected deliverable of 292 MWh/year is aproximatly the same as the consumption of 15 households

