

Energy Flexibility in Wastewater Treatment

Rasmus Halvgaard

Peter Tychsen, Thomas Munk-Nielsen,

Morten Grum, Henrik Madsen


CITIES, May 27, 2015

KRÜGER


 **VEOLIA**




Waste Water Treatment Plant (WWTP)



Waste-2-Energy



Kolding WWTP




Energy flexibility in waste water treatment and transport


- ① Sludge → biogas → gas turbine → electricity
- ② Power management of the aeration process (720 kW; >50%)
- ③ Pumps and storage in sewer system

Overall goal: minimize effluent concentrations and overflow risk

WWTP control architecture



Elspot prices



WWTP control goal

$$\text{minimize } p_{\text{fee}} Q^T S_N + p_{\text{elspot}}^T u$$

Activated Sludge Model (ASM) no. 1

$$\dot{S}_{NH} = -i_{XB}(\rho_1 + \rho_2) - \left(i_{XB} + \frac{1}{Y_A} \right) \rho_3 + k_a S_{ND} X_{B,H}$$

$$\dot{S}_{NO} = -\frac{1 - Y_H}{2.68 Y_H} \rho_2 + \frac{1}{Y_A} \rho_3$$

$$\dot{S}_O = -\frac{1 - Y_H}{Y_H} \rho_1 - \frac{4.57 - Y_A}{Y_A} \rho_3$$

$$\dot{S}_S = \rho_7 - \frac{1}{Y_H} (\rho_1 + \rho_2)$$

$$\dot{X}_S = (1 - f_p)(b_H X_{B,H} + b_A X_{B,A}) - \rho_7$$

$$\dot{X}_{B,H} = \rho_1 + \rho_2 - b_H X_{B,H}$$

$$\dot{X}_{B,A} = \rho_3 - b_A X_{B,A}$$

$$\dot{S}_{ND} = \rho_8 - k_a S_{ND} X_{B,H}$$

$$\dot{X}_{ND} = (i_{XB} - f_p i_{XP})(b_H X_{B,H} + b_A X_{B,A}) - \rho_8$$

(S_I , X_I , X_P , and S_{ALK})

Activated Sludge Model (ASM) no. 1 - reaction rates

$$\rho_1 = \hat{\mu}_H \frac{S_S}{K_S + S_S} \frac{S_O}{K_{O,H} + S_O} X_{B,H}$$

$$\rho_2 = \hat{\mu}_H \frac{S_S}{K_S + S_S} \frac{K_{O,H}}{K_{O,H} + S_O} \frac{S_{NO}}{K_{NO} + S_{NO}} \eta_g X_{B,H}$$

$$\rho_3 = \hat{\mu}_A \frac{S_{NH}}{K_{NH} + S_{NH}} \frac{S_O}{K_{O,A} + S_O} X_{B,A}$$

$$\begin{aligned} \rho_7 = k_h & \frac{X_S/X_{B,H}}{K_X + X_S/X_{B,H}} \left(\frac{S_O}{K_{O,H} + S_O} + \right. \\ & \left. \eta_h \frac{K_{O,H}}{K_{O,H} + S_O} \frac{S_{NO}}{K_{NO} + S_{NO}} \right) X_{B,H} \end{aligned}$$

$$\rho_8 = \rho_7 (X_{ND}/X_S)$$


Reduced ASM1 - time-varying linear model

$$\dot{S}_{NH} = \theta_{NH}^+ Q(t) w_i - \theta_{NH}^- O$$


$$\dot{S}_{NO} = -\theta_{NO}^- w_i + \theta_{NO}^+ O$$

$$(S_{NH}, S_{NO}) \geq 0$$


Model fit simple model, NH



Model fit simple model, NO




Aeration control




Sewer system control goal


$$\text{minimize overflow} + p_{elspot}^T f(Q)$$



Sewer system control: MPC simulation



Sewer system control: savings



WWTP Smart Grid challenges

- $(cost_{effluents}, cost_{overflow}) \gg cost_{electricity}$ (trade-off)
- Complex nonlinear time-varying process
- No forecasts of the incoming nutrients = load (sensors = \$\$\$)
- Time scale perspective (different markets and control handles)

Future work

- Energy management of flexible waste water treatment plants
- Real demonstrations
- Model Predictive Control of WWTP processes
- Control integration with sewer system and pumps
- Interface to power markets or aggregators
- WWTP aggregation strategies

Questions and Comments

Rasmus Halvgaard
rhal@dtu.dk

www.compute.dtu.dk/~rhal

Department of Applied Mathematics and Computer Science
Technical University of Denmark

