

# **Optimization of CHP and Thermal Storage under Heat Demand**

**(KIER Workshop)**


**2015. 10. 22**

**Konkuk University**

**Prof. Jong Bae PARK**

- **Optimal operating mode determination to maximize the profit of a district heating company considering physical characteristics of CHP and actual operational aspects**
- **Each operational mode of CCGT-based CHP is defined and modeled mathematically**
- **Optimal operating points of CHP are determined under Korea electricity market rules and other environments such as thermal load, fuel prices, heat price, etc.**
- **Thermal storage is included to determine the thermal/electrical output that maximize the profit during a period**


# Flow Chart of CHP Optimization



# CCGT-based Cogeneration System (1)

CHP

District Heat



## ■ Gas turbine(s) + HRSG + High/Low pressure Steam turbine(s)

- CHP: Various operations using several small-capacity gas turbines
- High efficiency can be maintained by separating steam turbines

## ■ Install Multiple District Heaters

- Increasing electrical output by optimizing extraction pressure
- Temperature of district heating water : 65°C/ 90°C/ 115°C

## ■ Optimize Seasonal Operation Mode

- Optimize heat/power efficiency by not operating low pressure turbine and condenser during high thermal load season
- Optimize heat/power efficiency by operating low pressure turbine and condenser during low thermal load season

## System (1)

### ■ MODE I : Heat-match mode (winter)

- Operating facilities: gas turbine, HRSG, high pressure steam turbine, district heater
- Not Operating facilities: Low pressure steam turbine, condenser

### ■ MODE II : Gas turbine operation mode (abnormal operation)

- Operating facilities: gas turbine (electricity only, no thermal output)
- Not Operating facilities: HRSG, high/low pressure steam turbine, condenser, district heater

### ■ MODE III : Electricity-match mode (summer)

- Operating facilities: gas turbine, HRSG, high/low pressure steam turbine, condenser
- Not Operating facilities: district heater
- CCGT operation only for electricity

# Operation Modes of Cogeneration System (2)

## ■ **MODE IV : Excessive Thermal Load Mode (Heat Emergency)**


- Operating facilities: gas turbine, HRSG, district heater
- Not Operating facilities: high/low pressure steam turbine, condenser
- Uses all heat recovery to supply thermal load (not electricity)

## ■ **MODE V : Mixed-match mode (spring/fall, low thermal load)**

- Operating facilities: gas turbine, HRSG, high/low pressure steam turbine, district heater

# Configuration of operation mode (1)


Operation mode- I






# Configuration of operation mode (2)

## Operation mode-III



# Configuration of operation mode (5)


## Operation mode- V



# Analysis Methodology (1)


Explore the optimum point equal to the thermal/electrical load  
(comparing the contribution margin from each operation mode within range of operation)

## <MODE I >



- ⊗○ Operational range of mode I is given above the thermal load (blue line)
- ⊗○ After meeting the thermal load, operating point is determined based on the electricity market revenue such as SMP, PSE, MGO(or DAOS)
- ⊗○ Excess heat is rejected to the environment through coolers or the exhaust gases (without thermal storage)

## <MODE III>




Thermal Load

Range of Operation  
=> Candidates ②


⊗○ Electrical output that can maximize the contribution margin is determined, and the thermal requirement could be met by the PLB, thermal storage except CHP

## <MODE V >




**After comparing the contribution margin at each mode (①, ②, ③), determine operation mode, electrical/thermal output**

# System Composition



<Electrical Demand>

Electricity Market Forecasting




<Heat Demand>



<CHP>

$\Rightarrow MODE_t, P_t, H_t$



<Thermal Storage>

$\Rightarrow TS_t^C, TS_t^D$

## [Objective Function]

$$\text{maximize } \sum_{t=1}^T \sum_{j=1}^3 \sum_{i=1}^N \left( SEP_{i,j,t} + GSCON_{i,j,t} + SCON_{i,j,t} + COFF_{i,j,t} \right) + HL_t \times HP_t - (a_{i,j}P_{i,j,t}^2 + b_{i,j}P_{i,j,t} + c_{i,j}) \times FP^{CHP}$$

$$SEP_{i,j,t} : SMP_t \times P_{SEP,i,j,t}$$

$$GSCON_{i,j,t} : \min(a_{i,j}P_{GSCON,i,j,t}^2 + b_{i,j}P_{GSCON,i,j,t}, SMP_t \times P_{GSCON,i,j,t})$$

$$SCON_{i,j,t} : \max(a_{i,j}P_{SCON,i,j,t}^2 + b_{i,j}P_{SCON,i,j,t} + c_{i,j}, SMP_t \times P_{SCON,i,j,t})$$

$$COFF_{i,j,t} : SMP_t \times P_{COFF,i,j,t} - (a_{i,j}P_{COFF,i,j,t}^2 + b_{i,j}P_{COFF,i,j,t} + c_{i,j})$$

SEP : Scheduled Energy Payment

GSCON : Payment by Market Price for Minimum Energy produced due to Generator-self Constraint

SCON : payment for energy produced due to System Constraints


COFF : Constrained-Off energy payment

## [Heat Balance Constraint]

$$HL_t \leq H_{i,j,t} - TS_t^C + TS_t^D$$

## [Operation Limits Constraint]

- ①  $H_{i,1,t} = \alpha_1 P_{i,1,t} + \beta_1$
- ②  $H_{i,5,t} \geq \alpha_{2,1} P_{i,5,t} + \beta_{2,1}$
- ③  $H_{i,5,t} \leq \alpha_{2,2} P_{i,5,t} + \beta_{2,2}$
- ④  $H_{i,5,t} \leq \alpha_{2,3} P_{i,5,t} + \beta_{2,3}$
- ⑤  $H_{i,5,t} \geq 0$






## [Thermal Storage Constraints]

$$TS^{min} \leq TS_t^C \leq TS^{max}$$

$$TS^{min} \leq TS_t^D \leq TS^{max}$$

$$SOC^{min} \leq SOC_0 + \sum_{k=1}^t (TS_k^C - TS_k^D) \leq SOC^{max}$$

## [Mode Change Time]




<example>

## Input Data (1)


No.	SMP [KRW/kWh]	PSE [MW]	MGO [MW]	Heat Load [Gcal/h]	No.	SMP [KRW/kWh]	PSE [MW]	MGO [MW]	Heat Load [Gcal/h]
1	124.0	887.4	887.4	264.6	13	70.2	0.0	608.6	372.1
2	119.3	572.1	662.4	264.6	14	121.0	0.0	637.4	413.5
3	119.1	0.0	662.4	264.6	15	121.0	0.0	662.4	415.2
4	120.4	0.0	887.4	264.6	16	119.2	0.0	698.8	320.4
5	129.8	0.0	887.4	264.6	17	117.6	0.0	887.4	300.8
6	130.7	887.4	887.4	304.7	18	129.8	887.4	887.4	280.3
7	130.4	887.4	887.4	350.0	19	130.7	887.4	887.4	273.8
8	130.4	887.4	887.4	478.6	20	130.7	887.4	887.4	283.5
9	74.2	0.0	635.0	478.6	21	129.8	887.4	887.4	304.7
10	129.8	887.4	624.0	430.2	22	130.7	887.4	887.4	253.1
11	129.8	887.4	732.2	430.2	23	130.7	887.4	887.4	253.1
12	129.8	887.4	715.9	372.5	24	130.7	600.0	887.4	253.1

Fuel Price [KRW/Gcal]	Heat Price [KRW/Gcal]
80,000	90,000



## Input Data (2)

[Heat - Power]



[Power - Fuel]

	a (QHC) [Gcal/MW <sup>2</sup> h ]	b (LHC) [Gcal/MWh]	c (NLHC) [Gcal/h]
MODEI	0.0002	1.329	291.01
MODEIII	0.0002	1.1763	252.75
MODEV	0.0003	1.0938	319.19


[Thermal  
Storage]

Hourly Discharge [Gcal/h]	Discharge Hours [h]	Total Capacity [Gcal]
190	8	1,520

## Result - Thermal Output - CHP (1)



## Result - Thermal Output - Thermal Storage (2)




## Result - Thermal Output (3)

NO.	Heat Load [Gcal/h]	with TS			without TS
		CHP	TS_C	TS_D	CHP
1	450.0	450.00	-	-	450.00
2	400.0	400.00	-	-	400.00
3	260.0	262.15	2.15	-	342.50
4	260.0	342.50	82.50	-	342.50
5	260.0	262.15	2.15	-	342.50
6	300.0	490.00	190.00	-	503.18
7	350.0	454.68	104.68	-	503.18
8	480.0	422.84	-	57.16	503.18
9	480.0	290.00	-	190.00	480.00
10	500.0	422.84	-	77.16	503.18
11	430.0	422.84	-	7.16	503.18
12	370.0	422.84	52.84	-	503.18

NO.	Heat Load [Gcal/h]	with TS			without TS
		CHP	TS_C	TS_D	CHP
13	365.0	262.15	-	102.85	365.00
14	200.0	342.50	142.50	-	342.50
15	150.0	340.00	190.00	-	342.50
16	120.0	262.15	142.15	-	342.50
17	300.0	262.15	-	37.85	342.50
18	280.0	422.84	142.84	-	503.18
19	273.0	459.31	186.31	-	503.18
20	283.0	422.84	139.84	-	503.18
21	305.0	422.84	117.84	-	503.18
22	253.0	422.84	169.84	-	503.18
23	253.0	422.84	169.84	-	503.18
24	265.0	421.69	156.69	-	421.69
<b>SUM</b>	<b>7587.0</b>	<b>9107.0</b>	<b>1992.2</b>	<b>472.2</b>	<b>10552.3</b>

## Result - Electrical Output(1)





## Result - Electrical Output (2)

NO.	without TS	with TS
1	660.28	660.28
2	553.83	553.83
3	431.41	260.37
4	431.41	431.41
5	431.41	260.37
6	773.50	745.44
7	773.50	670.25
8	773.50	602.46
9	724.15	319.65
10	773.50	602.46
11	773.50	602.46
12	773.50	602.46
13	479.32	260.37
14	431.41	431.41
15	431.41	426.10
16	431.41	260.37

NO.	without TS	with TS
17	431.41	260.37
18	773.50	602.46
19	773.50	680.11
20	773.50	602.46
21	773.50	602.46
22	773.50	602.46
23	773.50	602.46
24	600.00	600.00
<b>SUM</b>	<b>15,319.45</b>	<b>12,242.45</b>


[1000KRW]	Profit
with TS	222,019
without TS	194,820
	<b>27,199 (+14%)</b>

## ■ Present optimization system

- 1 CHP(3/5 modes), 1 thermal storage, heat demand, electricity market forecasting
- Implementation: MATLAB, CPLEX MILP

## ■ Future works

- Constraints of mode change time
- Termination condition of thermal storage
- Optimization considering multiple CHPs, Peak Load Boilers and other heat sources
- ESS(electrical Energy Storage System) so that electrical output is also optimized in electricity market



**Thank You**

---